



March 15, 2019

Re: Glencoe Public Library  
320 Park Ave.  
Glencoe, IL 60022  
Project No. 18018

### **ADDENDUM NO. 1**

The following revisions, clarifications, and/or additions are hereby made to the Contract Documents, and shall be considered as becoming a part of the Construction Documents:

Contract:

1. A Certificate of Insurance is required, but there is not a requirement for a specific dollar amount for liability coverage.
2. There is no payment of liquidated damages required.

Sitework:

1. The water line connection to the main is under the existing north brick paver public sidewalk. The bricks will need to be removed, stored, and then reset on a sand bed as required after waterline work is completed. The path for construction access from the curb to the excavation point against the building will need to be protected with plywood. Any landscaping involving removing or replanting of bushes or grass will be by the owner. Fill in of the excavation area by contractor will be to rough grade. Refer to the Site Plan sketch SK1.0.

Finishes:

1. The quartz countertops are to be by Silestone and be white. White samples are to be submitted for approval.

Plumbing:

1. The existing water service line is to be abandoned and disconnected from the main, which is located about 50 feet straight north from the basement water meter under the existing public sidewalk. The new copper water line will be directionally bored underground into the existing Basement. It will enter the Basement in the same room but more east to avoid excavating the front brick entry area. The actual connecting of the new water line into the main will be done by the Village, but all other water line work will be done by the contractor. Refer to the Site Plan sketch SK1.0.
2. All interior pipes from the new water service to all the new bath fixtures are to be replaced with copper pipes and sized as required.
3. Provide a \$750 allowance for each in-wall carrier support for the wall hung toilets.

---

**R. SCOTT JAVORE & ASSOCIATES, LTD.**

Glencoe Public Library

March 15, 2019

Page 2

**Bids are due on Tuesday, March 19, 2019, at 11 AM and are to be submitted to the Library per the directions in the Bid Document Packet.** The Contractor is to acknowledge receipt of this Addendum & sketch SK1.0 on the bid form. Please contact me if you have any questions regarding these modifications or the project in general.

Submitted by:

Michael Muenchow

---

**R. SCOTT JAVORE & ASSOCIATES, LTD.**

847 .835. 4442 // 333 PARK AVENUE, SUITE 300, GLENCOE 60022 // JAVOREARCHITECTS.COM